

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 626

Dated: 27.06.23

It is certified that an inspection team headed by MR. SHWETANK CHAURASIA
(Name of Officers with designation) from ASST. Engineer, PUBLIC HEALTH DEPT, SAGAR
(Name of Department/ Office) inspected the MAHAR REGIMENT PUBLIC SCHOOL, SAGAR
(Name & Address of the school) on 26.06.23 (date of inspection), checked the water test report
submitted by the school and found that the school has potable drinking water for students and staff of the
institution and is having provision for running water in the toilets and maintaining hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
The above is valid for a period of Four year (4 year)

Signature with Seal: 27/06/23

Name

: SHWETANK CHAURASIA

Designation

: ASSISTANT ENGINEER

Assistant Engineer of

the Govt. Public Health Department (PHED)/

Authorised officer of the Local Body

Name & Address of the Office / Department : PHED

GOPAL GANJ, SAGAR

Ash Jain
PRINCIPAL
Maha Regiment Public
School Sagar (M. P.)

To

PRINCIPAL

MAHAR REGIMENT PUBLIC SCHOOL, JHANSI ROAD, SAGAR, M.P.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**Public Health Engineering Department, P.H.E.D.
Near Tahseel Sagar
Test Report**

Nature of sample :- Drinking Water Sample / Others	Not sampled by District Water testing Lab		Unique Identification No.	
Sender's name and address: Principal mahar regiment public school sagar(mp)	Sender's letter no.	11	Sender's letter Date	26/6/23
	DWTL Ref. No	24/23	DWTL receipt date	26/6/23
	Date of analysis started	26/6/23	Date of analysis completed	27/6/23
	Quantity Of sample	2 LTR.		

Sample details

Particulars of Samples :-				
No.	Block	Panchayat	Village	Location
1	sagar	kudari	garphchra	In school bore well
2				
3	-	-	-	-
4	-	-	-	-
5	-	-	-	-

RESULTS

No.	Characteristics, unit and test methods	BIS -10500:2012		Test Results				
		Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4					
1*	Chloride as Cl in mg/l. (IS 3025 Part 32)	250	1000	30	-	-	-	-
2*	Total Alkalinity as CaCO ₃ in mg/l. (IS 3025 Part 23)	200	600	35	-	-	-	-
3*	Calcium as Ca++, in mg/l. (IS 3025 Part 40)	75	200	32	-	-	-	-
4*	Magnesium as Mg++, in mg/l. (IS 3025 Part 46)	30	100	9.6	-	-	-	-
5*	Total hardness as CaCO ₃ in mg/l. (IS 3025 Part 21)	200	600	120	-	-	-	-
6	pH (pH scale)	6.5 to 8.5	6.5 to 8.5	7.2	-	-	-	-
7	Iron as Fe Mg/l	1.0	1.0	0.10	-	-	-	-
8	Nitrate as NO ₃ Mg/l	45	45	0.25	-	-	-	-
9	Fluoride as F Mg/l	1.0	1.5	0.05	-	-	-	-
10	TDS Mg/l	500	2000	240.2	-	-	-	-
11	Turbidity NTU	1.0	5.0	1.1	-	-	-	-
12	Sulphate as SO ₄ Mg/l	200	400	3.5	-	-	-	-
13	Manganese as Mn Mg/l	0.1	0.3	0.0	-	-	-	-
14	Faecal Coliform (TTC) per 100 ml	NIL		0.0	-	-	-	-
15	Total Coliform per 100 ml	NIL for treated water and water in distribution system		0.0	-	-	-	-
16	Arsenic By Kit Mg/l	0.01	0.01	0.0	-	-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 7 days from the date of issue of report. (For tests from S.No. 1 to 17)
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
6. The tests marked with an * are accredited by NABL.

Remark:-

Neelam Rai
NEELAM RAI
TECHNICAL MANAGER
DISTRICT WATER
TESTING LABORATORY
P.H.E. DEPT., SAGAR

Shiwetank Choudhuria
SHIWETANK CHOUDHURIA
QUALITY MANAGER
DISTRICT WATER
TESTING LABORATORY
P.H.E. DEPT., SAGAR